


Note 1: Water Tanks located adjoining Pump Houses are 40'6" in diameter, 32' high, capacity of 300,000 gallons and equipped with Varec, Automatic tank gauge.
 Note 2: Both Pump Houses had regulated gas supply to gas boilers - no meter present. Gas supply is 2"

ELECTRIC METERS			
Ref	Unit	Tenant	Number
1		Unknown	5002954647

GAS METERS			
Ref	Unit	Tenant	Number
1		Inter Design	32762934

WATER METERS			
Ref	Unit	Tenant	Number
1		Unknown	MTU

INDUSTRIAL PROPERTY	
ACME Industrial	
Utility Plan	
CI-IR-001-001	 www.caoilte.com
Rev. 0	
Date: 7/11/2022	